

# Energy performance certificate (EPC)

|                                                                           |                           |                                                                                |
|---------------------------------------------------------------------------|---------------------------|--------------------------------------------------------------------------------|
| Flat 41<br>Nautilus Apartments<br>2 Norah Smyth Road<br>LONDON<br>E16 1FE | Energy rating<br><b>B</b> | Valid until: 7 June 2033<br><hr/> Certificate number: 0390-3988-0060-2707-4571 |
|---------------------------------------------------------------------------|---------------------------|--------------------------------------------------------------------------------|

**Property type**  
Mid-floor flat

**Total floor area**  
51 square metres

**Rules on letting this property**


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

**Energy rating and score**

This property's current energy rating is B. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)



The graph shows this property’s current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property’s energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description                                                             | Rating    |
|----------------------|-------------------------------------------------------------------------|-----------|
| Walls                | Average thermal transmittance 0.20 W/m²K                                | Very good |
| Windows              | High performance glazing                                                | Very good |
| Main heating         | Community scheme                                                        | Very good |
| Main heating control | Charging system linked to use of community heating, programmer and TRVs | Good      |
| Hot water            | Community scheme                                                        | Very good |
| Lighting             | Low energy lighting in all fixed outlets                                | Very good |
| Air tightness        | Air permeability 1.8 m³/h.m² (as tested)                                | Very good |

| Feature           | Description            | Rating |
|-------------------|------------------------|--------|
| Roof              | (other premises above) | N/A    |
| Floor             | (other premises below) | N/A    |
| Secondary heating | None                   | N/A    |

## Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO<sub>2</sub>. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Community combined heat and power

## Primary energy use

The primary energy use for this property per year is 38 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [About primary energy use](#)

### How this affects your energy bills

An average household would need to spend **£412 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £0 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Heating this property

Estimated energy needed in this property is:

- 9 kWh per year for heating
- 1,830 kWh per year for hot water

## More ways to save energy

[Find ways to save energy in your home.](#)

### Environmental impact of this property

This property's current environmental impact rating is A. It has the potential to be A.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

## Carbon emissions

**An average household produces**

6 tonnes of CO2

---

**This property produces**

0.4 tonnes of CO2

---

**This property's potential production**

0.4 tonnes of CO2

---

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Changes you could make

The assessor did not make any recommendations for this property.

[Simple Energy Advice has guidance on improving a property's energy use.](https://www.simpleenergyadvice.org.uk/)  
(<https://www.simpleenergyadvice.org.uk/>)

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme](https://www.gov.uk/apply-boiler-upgrade-scheme) (<https://www.gov.uk/apply-boiler-upgrade-scheme>). This will help you buy a more efficient, low carbon heating system for this property.

### Who to contact about this certificate

## Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

### Assessor's name

Nicola Griggs

---

### Telephone

0330 124 9271

---

### Email

[nicola.griggs@stroma.com](mailto:nicola.griggs@stroma.com)

---

## Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

### Accreditation scheme

Elmhurst Energy Systems Ltd

---

### Assessor's ID

EES/027209

---

### Telephone

01455 883 250

---

### Email

[enquiries@elmhurstenergy.co.uk](mailto:enquiries@elmhurstenergy.co.uk)

---

# About this assessment

## Assessor's declaration

No related party

---

## Date of assessment

8 June 2023

---

## Date of certificate

8 June 2023

---

## Type of assessment

► [SAP](#)

---

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.